ROGLA GmbH
Siemensstraße 5, 59199 Bönen, Germany
+49 151 67605803 · info@rogla-gmbh.de · rogla-gmbh.de
DISTRIBUTOR

Certificate of Analysis (CoA) · R32

ROGLA distributor edition (English) · cover page + enclosed manufacturer original

Product	R32
Batch (as printed on the certificate)	**20260930**
Sampling date	2026-09
Manufacturer and issuer of the analysis	Hangzhou Icetop Refrigeration Co., Ltd. (brand ARKOOL)
Distributor	ROGLA GmbH
Language of the certificate	English (original)

About this edition. ROGLA GmbH is the distributor only. ROGLA did not perform, issue or sign this analysis. The analysis results, signature and stamp are those of the manufacturer on page 2. This cover page was added by ROGLA; page 2 encloses the manufacturer's original certificate (image) unmodified. The certificate is valid only for the batch printed on it, not for all stock – please match the batch number with the label on your delivered cylinder and contact us for other batches.

Enclosed original: coa-r32-batch-20260930-arkool.png · SHA-256
7ab7543f3af55fd0de56baa3825235bec4fef708fbe08bb9d219187f2cdbc5bf
Edition date: 2026-10-24

杭州冰峰制冷有限公司
HANGZHOU ICETOP REFRIGERANTION CO.,LTD.
Tel：+8613735592463 Email: cg@ecmrefrigerant.com

ARKOOL
REFRIGERANT

CERTIFICATE OF ANALYSIS

Sample name: REFRIGERANT GAS R32 **BATCH NO: 20260930**
Sample source: 9KG CYLINDER **Produce time: Sep,2026**
Test standard: as following **Sampling time: Sep,2026**

Density items	Standard demands	Results
Smell	Colourless and no smelling	Colourless and no smelling
Appearance	Colourless and not turbid	Colourless and not turbid
R32	≥99.8	99.99
Moisture%	≤0.001	0.00085
Evaporation residue%	≤0.01	0.0008
Acidity (as HCl) %	≤0.0001	≤0.0001
Fouling gas %	≤1.5	0.19
Final conclusion: Conformity		
Tester：Feifei Duan Checker：Feifei Duan Auditor： Yueyin Zhang		